



		RUN SIZE									
		4	6	8	10	12	14	16	18	20	24
BRANCH SIZE	4	*	*	*	*	*	*	*	*	*	*
	6		*	*	*	*	*	*	*	*	*
	8			*	*	*	*	*	*	*	*
	10				*	*	*	*	*	*	*
	12					13	*	*	*	*	*
	14						24	13	*	*	*
	16							36	25	14	*
	18								47	37	16
	20									58	39
	24										79

* -FOR THIS CONDITION
NEED ONLY RESTRAIN THE
BRANCH OUTLET OF THE TEE.

RESTRAINED LENGTHS, "L" (IN FEET)

1. RESTRAIN THE TWO MECHANICAL JOINTS ON THE RUN SIDES OF THE TEE. WHEN LESS THAN A FULL 20' LENGTH OF PIPE IS INSTALLED ON EACH SIDE OF THE RUN.
2. ALL JOINTS WITHIN THE LENGTH "L" ON THE BRANCH MUST BE RESTRAINED. USE RETAINER GLAND AT MECHANICAL JOINTS AND HARNESS ON PUSH-ON PIPE PER CITY SPECIFICATION.
3. FOR TEST PRESSURES AND LAYING CONDITIONS SEE SECTION 22 OF GENERAL CONDITIONS.