



- NOTES :
1. METAL HOUSING SHALL BE PRIMED AND PAINTED WITH A LIGHT GREEN, TAN OR GRAY EXTERIOR ENAMEL FINISH.
 2. VALVE ASSEMBLY AND METAL HOUSING SHALL BE LOCATED IN MEDIAN ISLANDS, LANDSCAPE AREAS OR OUTSIDE OF SIDEWALK AREA WHERE POSSIBLE.

PROVIDE 4' MIN. SIDEWALK CLEARANCE ADJACENT TO AIR-VAC DEVICE FOR ADA ACCESSIBILITY REQUIREMENTS.

AUTOMATIC AIR RELEASE AND VACUUM VALVE

REF. & REV.
DEC., 2003

CITY OF FRESNO
W-13