



METER BOX SPECIFICATIONS	
CRISTY (FORNI DIV.) B16 BOX WITH G30 LID	OR
BROOKS NO. 37 WITH NO. 37 "H" COVER & CAST IRON LID	

ALL COPPER FITTINGS SHALL BE FLARE-TYPE.
ON POLYETHYLENE PIPE, USE COMPRESSION
JOINTS WITH STAINLESS STEEL INSERT.

NOTE:
FOR PVC PIPE TAPS, SERVICE SADDLES WITH
CIRCUMFERENTIAL TYPE BANDS SHAPED
TO FIT THE ACTUAL O.D. OF THE PIPE
AND HAVING A MINIMUM BEARING WIDTH
OF 3" (1 1/2" PER BAND) SHALL BE USED.

NOTE:
WATER SERVICES SHALL NOT BE ALLOWED IN DRIVEWAY
APPROACH AREAS AT ANY RESIDENTIAL LOCATION.

* NO. 37 "H" CAST IRON TRAFFIC COVER TO BE USED WHEN
METER IS LOCATED IN ALLEYS OR DRIVEWAY AREAS
OR BEHIND ROLLED CURBS

1" SERVICE CONNECTION & METER BOX INSTALLATION

REF. & REV.
NOV., 2007

CITY OF FRESNO
W-2