



MATERIALS LIST:

- | | |
|--|---|
| 1. 1"X 3/4" BRASS BUSHING - 2 REQ'D. | 8. 5/8" METER - 1 REQ'D. |
| 2. 3/4" J-1550 BRASS COUPLING - 2 REQ'D. | 9. 3/4" METER CONNECTION (TAIL PIECE) - 2 REQ'D. |
| 3. 3/4" COPPER TUBING - 2 REQ'D. | 10. 3/4" J-200 CURB STOP - 1 REQ'D. |
| 4. 3/4" J-1531 BRASS COUPLING - 2 REQ'D. | 11. 3/4" BRASS 90° ELL - 1 REQ'D. |
| 5. 3/4" BRASS TEE - 1 REQ'D. | 12. 3/4" BRASS CLOSE NIPPLE - 4 REQ'D. |
| 6. 3/4" BENT NOSE HOSE BIBB - 1 REQ'D. | 13. WEIGHTED DETECTOR CHECK VALVE - 1 REQ'D. |
| 7. 3/4" CHECK VALVE - 1 REQ'D. | A. TO BE INSTALLED BY DEVELOPER. |
| | B. TO BE TAPPED AND PLUGGED FOR
DETECTOR METER PIPING. SEE W-16. |