



NOTE:  
 WHEN REQUIRED BY THE ENGINEER THE CONTRACTOR SHALL FILL AND/OR GRADE AREA BETWEEN NEW GUTTER AND EXISTING STREET SURFACE WITH A.C. SURFACING TO A MIN. DEPTH OF 4" TO MEET EXISTING STREET SURFACING. COMPACTION SHALL BE MADE TO THE SATISFACTION OF THE ENGINEER. CLEAN FACE OF EXIST CURB BEFORE POURING CONCRETE GUTTER.

NOTE:  
 WHERE SIDEWALK IS NOT CONSTRUCTED, CUT OR FILL FROM 1" BELOW TOP OF CURB TO PROPERTY LINE AT A SLOPE OF 1/4" PER FOOT. A STEEPER SLOPE OF UP TO 10% MAY BE USED IN EXISTING RESIDENTIAL NEIGHBORHOODS WHERE (1) THE CONSTRUCTION OF SIDEWALK IS NOT EXPECTED IN THE FUTURE, (2) THE STEEPER SLOPE IS COMPATIBLE WITH THE ADJACENT PROPERTY, AND (3) THE STEEPER SLOPE WILL ELIMINATE THE NEED FOR A RETAINING WALL. SLOPES IN EXCESS OF 10% MAY BE APPROVED BY THE PUBLIC WORKS DIRECTOR ON A CASE-BY-CASE BASIS. 4' MINIMUM SIDEWALK FOR LOCAL STREETS AND 6' MINIMUM SIDEWALK FOR MAJOR STREETS.

SECTION-SECTION OF SIDEWALK, CURB & GUTTER

PROPERTY LINE  
 VARIABLE, SEE PLAN  
 SLOPE = 1/4" PER FOOT  
 CONCRETE SIDEWALK (4' WIDE, MINIMUM FOR LOCAL STREETS) (6' WIDE, MINIMUM FOR MAJOR STREETS, A 2' PE MAY BE REQUIRED)  
 AREA BETWEEN CURB & SIDEWALK SHALL BE FILLED TO 1" BELOW TOP OF CURB WITH CLEAN TOP SOIL FREE OF DEBRIS.  
 CONCRETE CURB & GUTTER  
 VARIABLE, SEE PLAN  
 SLOPE = 1/4" PER FOOT  
 CURB GRADE  
 GUTTER GRADE  
 STREET SURFACE

CONSTRUCTION DETAILS  
 FOR CONCRETE SIDEWALK, CURB  
 & GUTTER

REF. & REV.  
 SEPT., 2009

CITY OF FRESNO  
 P-5