



NOTE:

1. ALL FITTINGS SHALL BE SECURED WITH RETAINING GLANDS, HARNESSSES OR TIE-RODS AS APPLICABLE.
2. PLACE VALVES AND BLOW-OFFS OUTSIDE SIDEWALK AND DRIVEWAY AREAS.
3. ALL PUMP DISCHARGES SHALL BE FLANGED STEEL
4. ALL RISERS SHALL BE FLANGED, 6" DIAMETER.

BLOW-OFF SCHEDULE	
PIPE SIZE	
MAIN	BLOW-OFF
6"	4"
8"	4"
10"	4"
12"	6"
14"	6"
16"	6"

BLOW-OFF ASSEMBLY
TYPE B

REF. & REV.
AUG., 2002

CITY OF FRESNO
W-10