



- NOTES:
1. CHECK VALVE TO BE HERSEY MODEL E.D.C. OR D.C., GRINNELL MODEL A-2 OR B-2 OR APPROVED EQUAL.
 2. CHECK VALVE TO BE TAPPED AND PLUGGED (FOR INSTALLATION OF BYPASS METER PIPING BY CITY FORCES).
 3. VAULT OR BOX TO BE CHRISTY, BROOKS OR APPROVED EQUAL.
 4. VAULT OR BOX, DETECTOR CHECK VALVE AND COVER TO BE INSTALLED BY DEVELOPER'S CONTRACTOR PER FRESNO MUNICIPAL CODE, SECTION 14, SUBSECTIONS 131-137 INCL. SEE W-17 FOR DETAILS.
 5. VAULT OR BOX COVER TO HAVE 5"X 7" HINGED METER READ LID.

NOMINAL INSIDE DIMENSIONS

SERVICE	A	B
4" - 8"	30"	48"
10"	48"	48"