



FPD-H-4

## MALL/STREET SHOWS AND EXHIBIT REQUIREMENTS

(Revision: 09/15/08)

1. Large events require submittal of a scaled site plan for review five (5) working days prior to the event.
2. The central area of the mall, street, or public way is a Fire Department access road and must be maintained to a clear width of 20 feet. No vehicles are to be left parked on the access road except temporarily, to load and unload supplies.
3. Each booth using electrical lamps, appliances, etc., and/or any type of cooking equipment must have on the premises a minimum 2-A:10-B:C rated portable fire extinguisher which has been inspected and tagged within the past year.
4. No flammable or combustible liquids may be utilized for cooking or other purposes. LPG containers shall be limited to a maximum capacity of 25 gallons aggregate per booth. Empty LPG containers are prohibited on the mall.
5. Each booth used for cooking must have a minimum of 10 feet of clear space between adjacent booths.
6. Booths must be located a minimum of 10 feet from any building.

**Note:** Any projections, awnings, or canopies are considered to be part of the building to which they are affixed. Booths may not block exits from buildings along the mall, street, or public way.

7. No electrical cords are permitted across the center of the public way. Electrical cords extending to adjacent stores must be taped down or otherwise covered to protect pedestrians.
8. Tent structures may require a permit from the Development Department.
9. All compressed gasses (i.e., Helium or CO<sub>2</sub>) must be secured from falling.

If you have any questions or require additional information, please call the Fresno Fire Prevention Division at (559) 621-4181.