



**KERRI L. DONIS, CFO, EFO, MSOL
FIRE CHIEF**

Theodore F. Semonious, Deputy Fire Chief/Fire Marshal
Prevention and Technical Services Division
(559) 621-4181 ♦ FAX (559) 498-4323
Fresno Fire Department ♦ 911 H Street ♦ Fresno, CA 93721-3082

FIRE INDUSTRY BULLETIN 2016-007

SCOPE

New fire alarm plan submittal requirements for contractors, engineers, and other stakeholders.

PURPOSE

The purpose of this industry bulletin is to notify applicable stakeholders of the upcoming requirement for all firms to prepare fire alarm plans in accordance with FFD Policy No. 401.012.

BACKGROUND

As noted in the California Fire Code (CFC), the fire code official has the authority to formulate policies they deem necessary based upon local conditions related to plan submittals for all systems, including fire alarm systems.

The City of Fresno Fire Department has been in receipt of permit applications that have been found to be deficient for basic requirements.

To attempt to minimize some of the most common errors, the Department will begin requiring firms prepare fire alarm system submittals in accordance with FFD Policy No. 401.012. It is the Department's intent to help stakeholders reduce the number of plans that have to be returned for errors or omissions, and help reduce plan review times for all plan submittals.

INFORMATION

Beginning October 1, 2016, all firms shall prepare fire alarm plans per FFD Policy No. 401.012.

NOTE

This notice is effective September 16, 2016.

"To protect and put service above all else."



City of Fresno Fire Department

Fire Alarm Equipment List Sample

NEW DEVICE QUANTITY	SYMBOL	DESCRIPTION	MODEL	MANUFACT.	CSFM #	ELECT. REQ'D
MAIN ELECTRICAL EQUIPEMENT						
00	[FACP]	FIRE ALARM CONTROL PANEL				
00	[NAC#]	REMOTE POWER SUPPLY				
00	[FATC]	FIRE ALARM TERMINAL CAN				
00	[FAA]	FIRE ALARM ANNUNCIATOR				
INITIATING DEVICES						
00	[P]	PHOTOELECTRIC DETECTOR				
00	[F]	HEAT DETECTOR				
00	[F]	MANUAL PULL STATION				
00	[PDS]	PHOTOELECTRIC DUCT SMOKE DETECTOR				
INDICATING DEVICES						
02	[15]	15 CANDELA - WALL MOUNT HORN/STROBE				
00	[30]	30 CANDELA - WALL MOUNT HORN/STROBE				
02	[75]	75 CANDELA - WALL MOUNT HORN/STROBE				
00	[95]	95 CANDELA - WALL MOUNT HORN/STROBE				
00	[110]	110 CANDELA - CEILING MOUNT HORN/STROBE				
00	[115]	115 CANDELA - CEILING MOUNT HORN/STROBE				
00	[15]	15 CANDELA - WALL MOUNT STROBE				
00	[30]	30 CANDELA - WALL MOUNT STROBE				
02	[15]	15 CANDELA - CEILING MOUNT STROBE				
00	[30]	30 CANDELA - CEILING MOUNT STROBE				
00	[75]	75 CANDELA - CEILING MOUNT STROBE				
MONITORING, CONTROL & RELAY MODULES						
00	[AIM ₁]	WATERFLOW SWITCH/TAMPER SWITCH MONITORING INTERFACE DEVICE				
00	[AIM ₂]	FIRE PUMP MONITORING INTERFACE MONITORING INTERFACE DEVICE				
00	[AIM ₄]	ELEVATOR SHUNT/TRIP CIRCUIT MONITORING INTERFACE DEVICE				
00	[AIM ₅]	ANSUL SYSTEM MONITORING INTERFACE DEVICE				
00	[ACM ₁]	AC & FIRE SMOKE DAMPER CIRCUIT RELAY MODULE				
00	[ACM ₂]	DOOR HOLDER INTERFACE RELAY MODULE				
00	[ACM ₃]	ELEVATOR CONTROL RELAY MODULES				
00	[ACM ₄]	SHUNT/TRIP CIRCUIT CONTACTS				
REFERENCE DEVICES						
00	[DH]	MAGNETIC WALL MOUNT DOOR HOLDER				
00	[AHU]	AIR HANDLER UNIT				
00	[FSD]	FIRE SMOKE DAMPER				
00	[WF]	WATERFLOW SWITCH				

